

PERMITTEE NAME / ADDRESS (Include Facility Name / Location if Different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT

NAME Lyons East (No. 1) WPCP

ADDRESS 161 N.E. Broad Street
Lyons, GA 30436

FACILITY Lyons East (No. 1) WPCP
LOCATION 290 E. Thomson St, Toombs County, Lyons, GA 30436

GA0033405
PERMIT NUMBER

0011
DISCHARGE NUMBER


MINOR (SUBR CS) ALLIS

External Outfall

*** NO DISCHARGE: ***

MONITORING PERIOD							
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	2010	01	01		2010	01	31
	2012	04			2012	04	30

NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Oxygen, Dissolved (DO) 00300 1 0 Effluent Gross	*****	*****	*****	*****	6.3	*****	*****	(19) mg/l	0	05/07	Grab
	*****	*****	*****	*****	5.0 inst min	*****	*****			5 / wk	grab
BOD, 5-day (20 deg. C) 00310 1 0 Effluent Gross	9.3	19.2	(01) kg/d	*****	5.5	9.4	(19) mg/l	0	02/07	8+L	
	51 mo ave	64 wk ave		*****	20 mo ave	30 wk ave			2 / wk	composite	
BOD, 5-day (20 deg. C) 00310 G 0 Raw Sewage Influent	363	521	(01) kg/d	*****	228	250	(19) mg/l	***	02/07	8+L	
	report mo ave	report wk ave		*****	report mo ave	report wk ave			2 / wk	composite	
pH 00400 1 0 Effluent Gross	*****	*****	*****	6.55	*****	7.07	(12) SU	0	05/07	Grab	
	*****	*****	*****	6.0 min	*****	9.0 max			5 / wk	grab	
Solids, Total Suspended 00530 1 0 Effluent Gross	5.6	12.5	(01) kg/d	*****	3.3	6.2	(19) mg/l	0	02/07	8+L	
	76 mo ave	95 wk ave		*****	30 mo ave	45 wk ave			2 / wk	composite	
Solids, Total Suspended 00530 G 0 Raw Sewage Influent	351	543	(01) kg/d	*****	217	261	(19) mg/l	***	02/07	8+L	
	report mo ave	report wk ave		*****	report mo ave	report wk ave			2 / wk	composite	
Nitrogen, Ammonia Total (as N) 00610 1 0 Effluent Gross	1.31	1.67	(01) kg/d	*****	0.87	1.26	(19) mg/l	0	02/07	8+L	
	25 mo ave	32 wk ave		*****	10 mo ave	15 wk ave			2 / wk	composite	
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.				 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT			TELEPHONE		DATE	
John E. Moore, Sr Mayor Willis Nesmith TYPED OR PRINTED								(912) 526-3496		2012 04 30	
							AREA CODE & NO		YEAR MO DAY		

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here.)