

NAME City of Lyons  
ADDRESS 161 NE Broad Street  
Lyons, GA 30436  
FACILITY Lyons East Plant  
LOCATION Lyons, GA 30436

**GA0033405**  
PERMIT NUMBER


**000-1**  
DISCHARGE NUMBER

DMR MAILING ZIP CODE: **30436**  
MINOR  
(SUBR MM)  
ACTIVE  
External Outfall

MONITORING PERIOD  
FROM **1/1/2017** TO **1/31/2017**

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
<b>Oxygen, dissolved (DO)</b> <b>00300 1 0</b> <b>Effluent Gross</b>	SAMPLE MEASUREMENT	***	***	mg/l	<b>8.55</b>	***	***	mg/l		5 Days Every Week	GRAB
	PERMIT REQUIREMENT	***	***	mg/l	<b>5 MINIMUM</b>	***	***	mg/l		5 Days Every Week	GRAB
<b>BOD, 5-day, 20 deg. C</b> <b>00310 1 0</b> <b>Effluent Gross</b>	SAMPLE MEASUREMENT	<b>4.7</b>	<b>7.0</b>	kg/day	***	<b>2</b>	<b>2</b>	mg/l		2 Days Every Week	Composite
	PERMIT REQUIREMENT	<b>51 JAN-APR 25 MAY-NOV 51 DEC</b>	<b>63 JAN-APR 32 MAY-NOV 63 DEC</b>	kg/day	***	<b>20 JAN-APR 10 MAY-NOV 20-Dec</b>	<b>30 JAN-APR 15 MAY-NOV 30-Dec</b>	mg/l		2 Days Every Week	Composite
<b>BOD, 5-day, 20 deg. C</b> <b>00310 G 0</b> <b>Raw Sewage Influent</b>	SAMPLE MEASUREMENT	<b>193</b>	<b>259</b>	kg/day	***	<b>87</b>	<b>142</b>	mg/l		2 Days Every Week	Composite
	PERMIT REQUIREMENT	<b>Req. Mon. MO AVG</b>	<b>Req. Mon. WKLY AVG</b>	kg/day	***	<b>Req. Mon. MO AVG</b>	<b>Req. Mon. WKLY AVG</b>	mg/l		2 Days Every Week	Composite
<b>pH</b> <b>00400 1 0</b> <b>Effluent Gross</b>	SAMPLE MEASUREMENT	***	***	***	<b>6.3</b>	***	<b>7.2</b>	su		5 Days Every Week	GRAB
	PERMIT REQUIREMENT	***	***	***	<b>6 MINIMUM</b>	***	<b>8.5 MAXIMUM</b>	su		5 Days Every Week	GRAB
<b>Total Suspended Solids</b> <b>00530 1 0</b> <b>Effluent Gross</b>	SAMPLE MEASUREMENT	<b>6</b>	<b>14</b>	kg/day	***	<b>2</b>	<b>5</b>	mg/l		2 Days Every Week	Composite
	PERMIT REQUIREMENT	<b>76 MO AVG</b>	<b>95 WKLY AVG</b>	kg/day	***	<b>30 MO AVG</b>	<b>45 WKLY AVG</b>	mg/l		2 Days Every Week	Composite
<b>Total Suspended Solids</b> <b>00530 G 0</b> <b>Raw Sewage Influent</b>	SAMPLE MEASUREMENT	<b>172</b>	<b>331</b>	kg/day	***	<b>80</b>	<b>180</b>	mg/l		2 Days Every Week	Composite
	PERMIT REQUIREMENT	<b>Req. Mon. MO AVG</b>	<b>Req. Mon. WKLY AVG</b>	kg/day	***	<b>Req. Mon. MO AVG</b>	<b>Req. Mon. WKLY AVG</b>	mg/l		2 Days Every Week	Composite
<b>Nitrogen, Ammonia Total (asN)</b> <b>Effluent</b> <b>00610 1 0</b>	SAMPLE MEASUREMENT	<b>0.075</b>	<b>0.240</b>	kg/day	***	<b>0.033</b>	<b>0.112</b>	mg/l		2 Days Every Week	Composite
	PERMIT REQUIREMENT	<b>25 JAN-APR 5 MAY-NOV 25-Dec</b>	<b>32 JAN-APR 6 MAY-NOV 32 DEC</b>	kg/day	***	<b>10 JAN-APR 2 MAY-NOV 10-Dec</b>	<b>15 JAN-APR 3 MAY-NOV 15-Dec</b>	mg/l		2 Days Every Week	Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 <b>Trey Pearson</b> <b>FOR Larry Douglas</b>	TELEPHONE		DATE
<b>LARRY DOUGLAS</b> <b>OPERATOR</b>			912-449-0999	<b>2/14/2017</b>	
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	MM/DD/YYYY	

(Include Facility Name/Location if different)

**DISCHARGE MONITORING REPORT (DMR)**

OMB No. 2040-0004

NAME City of Lyons  
 ADDRESS 161 NE Broad Street  
Lyons, GA 30436  
 FACILITY Lyons East Plant  
 LOCATION Lyons, GA 30436


**GA0033405**  
 PERMIT NUMBER

**000-1**  
 DISCHARGE NUMBER

DMR MAILING ZIP CODE: **30436**  
 MINOR  
 (SUBR MM)  
 ACTIVE  
 External Outfall

**MONITORING PERIOD**  
 MM/DD/YYYY TO MM/DD/YYYY  
**1/1/2017** TO **1/31/2017**

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS				
<b>Flow, in conduit or thru treatment plant</b>  <b>50050 1 0</b> <b>Effluent Gross</b>	SAMPLE MEASUREMENT	<b>0.63</b>	<b>0.827</b>	mgd	***	***	***	***		5 Days Every Week	Continuous	
	PERMIT REQUIREMENT	<b>0.67</b> <b>MO AVG</b>	<b>0.838</b> <b>WKLY AVG</b>	mgd	***	***	***	***		5 Days Every Week	Continuous	
<b>Chlorine, total residual</b>  <b>50060 1 0</b> <b>CWL Effluent Gross</b>	SAMPLE MEASUREMENT	***	***	***	***	***	<b>0.010</b>	mg/l		2 Days Every Week	GRAB	
	PERMIT REQUIREMENT	***	***	***	***	***	<b>0.022</b> <b>DAILY MAX</b>	mg/l		2 Days Every Week	GRAB	
<b>Coliform, Fecal General</b>  <b>74055 1 0</b> <b>Effluent Gross</b>	SAMPLE MEASUREMENT	***	***	***	***	<b>1</b>	<b>1</b>	mpn/100 ml		1 Day Every Week	GRAB	
	PERMIT REQUIREMENT	***	***	***	***	<b>200</b> <b>MO GEO</b>	<b>400</b> <b>WKLY GEO</b>	mpn/100 ml		1 Day Every Week	GRAB	
<b>Solids, sludge, tot, dry weight</b>  <b>78477 S 0</b> <b>See Comments</b>	SAMPLE MEASUREMENT	<b>0.00</b>	***	Dry Ton	***	***	***	***		MONTHLY	CALCTD	
	PERMIT REQUIREMENT	<b>Opt. Mon.</b> <b>MO TOTAL</b>	***	Dry Ton	***	***	***	***		MONTHLY	CALCTD	
<b>BOD, 5-Day, Percent Removal</b>  <b>Removal</b> <b>81010 K 0</b>	SAMPLE MEASUREMENT	***	***	***	<b>98</b>	***	***	%		MONTHLY	CALCTD	
	PERMIT REQUIREMENT	***	***	***	<b>85</b> <b>MN % RMV</b>	***	***	%		MONTHLY	CALCTD	
<b>Solids, Suspended Percent Removal</b>  <b>Removal</b> <b>81011 K 0</b>	SAMPLE MEASUREMENT	***	***	***	<b>97</b>	***	***	%		MONTHLY	CALCTD	
	PERMIT REQUIREMENT	***	***	***	<b>85</b> <b>MN % RMV</b>	***	***	%		MONTHLY	CALCTD	
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.				TELEPHONE		DATE				
<b>LARRY DOUGLAS</b>  <b>OPERATOR</b>						 <b>Trey Pearson</b> <b>FOR Larry Douglas</b>		912-449-0999		<b>2/14/2017</b>		
TYPED OR PRINTED						SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	MM/DD/YYYY		

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)





FACILITY

**Lyons East Plant**

PERMIT NUMBER	MONITORING PERIOD		
<b>GA0033405</b>	MM/DD/YYYY	TO	MM/DD/YYYY
	<b>1/1/2017</b>		<b>1/31/2017</b>

OLIFORM	FECAL COLIFORM		BOD REMOVAL		TSS REMOVAL		AMMONIA EFFLUENT				SLUDGE
Avg. Wkly. Effluent	Monthly Effluent	Avg. Wkly. Effluent	Monthly Effluent	Avg. Wkly. Effluent	Monthly Effluent	Avg. Wkly. Effluent	Monthly Effluent	Avg. Wkly. Effluent	Monthly Effluent	Avg. Wkly. Effluent	
CONC	LOG	LOG	%	%	%	%	CONC	CONC	LOADING	LOADING	Sludge
	0.0000		98		98		0.025		0.06		
			95		96		0.000		0.00		
<b>1</b>		<b>0.00</b>		<b>97</b>		<b>97</b>		<b>0.01</b>		<b>0.03</b>	
	0.0000		98		93		0.0000		0.00		
			98		97		0.224		0.48		
<b>1</b>		<b>0.00</b>		<b>98</b>		<b>95</b>		<b>0.11</b>		<b>0.24</b>	
	0.0000		99		100		0.000		0.00		
			99		99		0.000		0.00		
<b>1</b>		<b>0.00</b>		<b>99</b>		<b>100</b>		<b>0.00</b>		<b>0.00</b>	
			97		85		0.016		0.05		
	0.0000		95		93		0.000		0.00		
<b>1</b>		<b>0.00</b>		<b>96</b>		<b>89</b>		<b>0.01</b>		<b>0.02</b>	
	0.0000		98		95		0.03		0.09		
											0.00
Concentration			BOD Removal		TSS Removal		EFF Concentration		EFF LOADING		
Wkly Fecal	Fecal LOG	Fecal LOG	MO. BOD	Wkly BOD	MO. TSS	Wkly TSS	MO. NH3	WKLY NH3	MO. NH3	WKLY NH3	Sludge
	0.0000	0.0000	98	97	97	95	0.03	0.03	0.08	0.07	0.00
<b>1</b>	0.0000	0.0000	98	99	97	100	0.22	0.11	0.48	0.24	0.00
	0.0000		98	96	98	89	0.00	0.00	0.00	0.00	0.00
			85		85		17.4		62.7		
							26.1		78.3		